



Tune Up Details

Inspections

- Inspect wiring connections for the compressor
- Inspect electrical disconnect box to ensure it's properly sized, not melted together
- Inspect indoor coil for visible corrosion
- Inspect bearing for wear and lubricate as needed
- Inspect exposed wiring for wear, connections, tighten as needed
- Inspect fan blade
- Inspect and test capacitors
- Inspect duct work for loose connections, or energy loss
- Inspect drain pan for leaks or holes
- Inspect service valves for proper operation
- Inspect and clean condenser coil
- Inspect and clean air filter as needed/capable

Tests

- Test thermostat for proper operation, calibrate and level
- Test refrigerant for proper operating pressures
- Test for level on outdoor and indoor units
- Test drain to ensure working properly
- Test and inspect contactor for burned or pitted contacts
- Test supply and return temperature differential
- Test and measure voltage/amp draw
- Test blower motor amperage for proper operation